MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

TEST – REPORT

Not for legal use

Lab No. : MCPHL/26/ 1396-

Date : 18.05.2026

Ref. No.	:	BTCHD/05/26/03	**Sample Details**	**Date & Time**
Dated	:	14.05.2026		
Issued to	:	The Principal Banyan Tree School Sector – 48,B, Chandigarh	Collected By :	Laboratory Staff
Location	:	From School tap of Banyan Tree School Sector – 48,B, Chandigarh	Collection Date :	15.05.2026 at 6:30p.m
Packing	:	Polypropylene and glass bottle	Received at Lab :	07:50p.m.

Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 – 8.5	——	7.59
2	Odour	Agreeable	——	Agreeable
3	Taste	Agreeable	——	Agreeable
4	Turbidity	<1	N.T.U.	0.8
5	Total Dissolved Solids	<500	mg/l	220
6	Residual Chlorine	0.2 – 0.4	mg/l	0.2
7	Total Alkalinity (as $CaCO_3$)	<200	mg/l	194
8	Total Hardness (as $CaCO_3$)	<200	mg/l	112
9	Chlorides (as Cl)	<250	mg/l	07
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No. 05/2026-27/319527, dated 14.05.2026, amount Rs.-3300/-

Note: - Water sample is found " **POTABLE** "

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Endst. No. MCPH/26/----------

Dated : 18.05.2026

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector -17, Chandigarh for Information please.

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or legal purpose.

------ End of Report ------

WATER IS LIFE, SAVE IT

BANYAN TREE SCHOOL Sector 48, Chandigarh