



DELHI JAL BOARD  
(GOVT. OF N.C.T. DELHI)  
QUALITY CONTROL ZONAL LABORATORY (SOUTH)  
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015

Ref. A.C.W.A.(South):-Paid/2024-25/P1-2/Challan no 484 Dt 27.03.2024

S. No 8112

Date: 08.04.2024

M/S BANYAN TREE SCHOOL  
3, LODHI INSTITUTIONAL AREA  
NEW DELHI-110003

Date of Sample collection :- 04.04.2024

S.No	Characteristics	Unit	Acceptable Limit	Permissible Limit	UGT NEAR RECEPTION	TAP DRINKING POINT NEAR ROOM NO 105
1.	Clarity	Unit	5	15	Clear	Clear
2.	Odour	---	Agreeable	Agreeable	Agreeable	Agreeable
3.	Turbidity	NTU	1	5	1.90	2.02
4.	pH Value	---	6.5-8.5	No relaxation	7.4	7.4
5.	Conductivity	$\mu\text{mho}/\text{cm}^2$	---	---	464	524
6.	Total Dissolved Solids	mg/L	500	2000	302	341
7.	Phenolphthalein Alkalinity	mg/L	----	----	NIL	NIL
8.	Total Alkalinity (as CaCO <sub>3</sub> )	mg/L	200	600	98	104
9.	Total Hardness (as CaCO <sub>3</sub> )	mg/L	200	600	128	144
10.	Carbonate hardness	mg/L	----	----	98	104
11.	Non- Carbonate Hardness	mg/L	----	----	30	40
12.	Calcium Hardness	mg/L	----	----	92	96
13.	Magnesium Hardness	mg/L	----	----	36	48
14.	Ammonia (as Total N)	mg/L	0.5	No relaxation	ND	ND
15.	Nitrite (as N)	mg/L	----	----	ND	ND
16.	Nitrate	Mg/L		45.0	3.1	3.0
17.	Sulphate (as SO <sub>4</sub> )	mg/L	200	400	40	44
18.	Chloride (as Cl)	mg/L	250	1000	46	56
19.	Iron	Mg/l	-	1.0	0.02	0.02
20.	Fluoride	mg/L	1.0	1.5	0.12	0.25
21.	Calcium (as Ca)	mg/L	75	200	36.8	38.4
22.	Magnesium (as Mg)	mg/L	30	100	8.64	11.52
23.	Free Residual Chlorine	mg/L	0.2	1	1.63	0.46

88/4/24  
ACWA (SOUTH ZONE)  
Dr. D. P. SINGH  
ACWA (SOUTH ZONE)  
Delhi Jal Board  
Govt. of NCT of Delhi

8/3/24  
CHEMIST

Manager  
Banyan Tree School  
3, Lodhi Institutional Area  
New Delhi-110003

A/CHEMIST  
Principal  
Banyan Tree School  
3, Lodhi Institutional Area  
New Delhi-110003


"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



OFFICE OF THE A.C.W.A (SOUTH ZONE)  
DELHI JAL BOARD  
( GOVT. OF N.C.T. DELHI )  
QUALITY CONTROL ZONAL LABORATORY (SOUTH)  
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015



Dated: 06.04.2024

No. DJB/DTQC/ CWA (W&S) III / ACWA (south)/ Bact./P.S./2024-2025/01-02/04.04.2024

**Bacteriological Analysis Report as per IS 10500:2012**

To Banyan Tree School  3 Lodhi Institutional Area  New Delhi - 110003	Party Ref.No./Date: NIL/Dt:27.03.2024 Deptt.Challan No. /date: 484/27.03.2024 Dt.of sample collection: 04.04.2024 No. of Sample: Two(02) Collected by: Sh. Nagendra Ojha Desig.- Lab./Tech.
--	--

SL.No.	Particulars	Clarity	Residual chlorine	Total coliform/ E.coli in 100 ml sample
1.	U.G.T Near Reception of the school	Clear	1.63	0
2.	Tap Drinking Point near room no.105 of the school	Clear	0.46	0

**RESULT:-** Collected water sample as mentioned above at Sr. No. 1&2 were found bacteriological satisfactory, hence the water/source is fit for drinking/recreational purpose subject to satisfactory attached Physical-Chemical Analysis report also.

06/04/22  
Dr. D P Singh  
ACWA (SOUTH ZONE)

Dr. D. P. SINGH  
ACWA (SOUTH ZONE)  
Delhi Jal Board  
Govt. of NCT of Delhi

06/04/24  
BACTERIOLOGIST DIXIT  
MANESHWAR DIXIT  
BACTERIOLOGIST (SOUTH ZONE)  
Delhi Jal Board  
Govt. of NCT of Delhi

06/04/24  
ASSTT/BACT.

Manager  
Banyan Tree School  
3, Lodhi Institutional Area  
New Delhi-110003

Principal  
Banyan Tree School  
3, Lodhi Institutional Area  
New Delhi-110003



MUNICIPAL CORPORATION OF DELHI  
PUBLIC HEALTH DEPARTMENT, CENTRAL ZONE  
SHIV MANDIR MARG, LAJPAT NAGAR, NEW DELHI

No.DHO/CNZ/2023/ 600

Dated: 19/7/23

SCHOOL HEALTH CERTIFICATE

Name of the school: **Banyan Tree School**

Address of School: 03, Lodhi Institutional Area New Delhi

Shifts: ONE Timing: MORNING

No. of Students: Boys: 386 Girls: 244 Total: 630

No. of Staff (Teachers): Female: 39 Male: 10 Total: 49

That the accommodation provided for the class rooms as calculated.

- (A) On floor space is sufficient Yes
- (B) On Cubic space is sufficient Yes
- That the classrooms are well ventilated Yes
- That the classrooms are kept eat and clean Yes
- That the classrooms are well lighted Yes


That the building is not in substantial repair in the class of NIL

- That the drinking water is wholesome Wholesome
- That the latrines arrangement is adequate and there are sufficient latrines.
- That urinals arrangement is adequate and there are sufficient urinals

This certificate is issued for sanitary and hygienic condition from health point of view of the school premises. This certificate has no bearing structure stability and fire safety. This certificate is valid for one year from the date of issue.

This certificate is only for this building.

  
Manager  
Banyan Tree School  
3, Lodhi Institutional Area  
New Delhi-110003

  
Dy. Health Officer  
Deputy Central Zone  
Central Zone, MCD

  
Principal  
Banyan Tree School  
3, Lodhi Institutional Area  
New Delhi-110003